

ORDINANCE NO. 890

An Ordinance Amending a Section of the Gas Code, City of Slidell,
Louisiana, Relative to Polyethelene Tubing.

BE IT ENACTED BY THE MAYOR AND CITY COUNCIL OF THE CITY OF
SLIDELL, LOUISIANA, IN LEGAL SESSION CONVENED:

Article 24 of Appendix B - Zoning, of the Code of Ordinances of City of Slidell,
Louisiana, is hereby amended and re-enacted to read as follows:

Article 24. Special Equipment

The use of underground copper tubing for outdoor gas illuminated
fixtures shall be approved with the following provisions:

The gas fixture shall be installed completely outdoors. The tubing
shall be continuous and shall be placed 9 inches or more under-
ground, and shall not be installed under any building or portion of
any building or structure. The connection to the fuel line shall be
steel pipe with a stop cock, stop-cock shall be installed to steel
pipe. An orifice restrictor shall be installed after the stop-cock
to limit the flow of gas to 5 cubic feet per hour or less. Connec-
tion from copper tubing to steel pipe shall be made above ground,
or connection made with insulating fitting to avoid electrolitic
action. Copper tubing extending above the ground shall be pro-
tected from mechanical injury by rigid support or other approved
method.

The fixture shall have an accessible shutoff valve or cock.

The authority in charge may require that all connections be ex-
posed until leak tests are witnessed. Permit shall be secured
before making installation, and fees charged shall be as shown
in Article 27.

Polyethylene tubing may be used for conveying natural gas under-
ground to outdoor appliances such as gas lights (for yard), gas
grills and incinerators. Such tubing shall be manufactured in
accordance with requirements for PE3306 tubing, pipe and fittings
ASTM designation D-2513-66T.

The polyethylene extrusion compound from which the tubing is
made shall meet the requirements of Type III, Grade 3, as des-
cribed in ASTM D-1248-60T, "Specification for Polyethylene Mold-
ing and Extrusion Compounds (which are referred to in CS255-63)."

The tubing shall be homogeneous throughout and free of visible
cracks, holes, foreign inclusions or other defects. It also shall
be uniform in color, opacity, density and other physical properties.

Special gas burning equipment not specifically mentioned herein,
such as boilers, various types of ovens, processing equipment
and other commercial and industrial equipment shall be installed:

- (1) On a firm foundation, easily accessible and so that there
will be ample space for inspcetion, repair or replace-
ments, and general operation and observance.

- (2) In conformance with requirements of Article 22.
- (3) So as to conform to the requirements as indicated in the building code of the National Board of Fire Underwriters.
- (4) With venting in accordance with Articles 24 and 25.

Article 27 (e) of Appendix B - Zoning, of the Code of Ordinances of City of Slidell, Louisiana, is hereby amended and re-enacted to read as follows:

Article 27 (e) Fees. Before a person, firm or corporation shall proceed with a gas installation or repair, he shall file a request for a permit with the city and pay the following fees which are due and payable upon application for permits.


These fees shall cover all inspections of the work for which a permit is issued, as well as the issuance of the certificate of approval. If, however, the inspector is forced to make an additional trip or trips to the work by reason of the fact that the work is not ready for inspection at the time he calls in compliance with the notice hereinabove referred to, then an additional special inspection fee, as indicated, shall be paid for each trip so made.

PERMITS AND INSPECTIONS FEES


	Each
Gas piping per 100' and 5 outlets.....	\$2.50
Additional outlets.....	1.00
Water heaters--domestic.....	1.00
Water heaters--commercial.....	2.50
Floor furnaces.....	1.00
Panel heaters.....	1.00
Unit heaters.....	2.50
Gas dryers--commercial.....	2.50
Gas dryers--domestic.....	1.00
Warm-air furnaces not over 200,000 BTU output.....	2.50
Warm-air furnaces over 200,000 BTU output.....	5.00
Commercial space heaters.....	2.50
Commercial ranges.....	2.50
Commercial ovens.....	2.50
Domestic ranges.....	1.00
Domestic ovens.....	1.00
Incinerators.....	2.50
Changing from liquefied petroleum gas to natural gas.....	2.50
Special Equipment--	
As defined in article special equipment.....	2.50
Installation of one unit from an existing outlet either exposed on the exterior of the structure or the gas meter...	2.50
Any additional unit installed from the same outlet.....	1.00
New gas outlet additional to permit fee.....	2.50
Special inspections.....	3.50

Special inspections such as when the inspections ~~such as when the inspector~~ is forced to make an additional trip or trips to the work by reason of the fact that work is not ready for inspection at the time he calls in compliance with the notice hereinabove referred to, shall warrant an additional fee.

Duly introduced and adopted this 14th day of November, 1972.


Frank N. Cusimano, Mayor

ATTEST:


John Swenson, City Clerk