

ORDINANCE NO. 917

An Ordinance Amending the National Building Code as Adopted by the City of Slidell in Ordinance No. 679-1, Section 1 on April 2nd, 1963, relative to Location of Fire Hydrant.

BE IT ENACTED BY THE MAYOR AND CITY COUNCIL OF THE CITY OF SLIDELL, LOUISIANA, IN LEGAL SESSION CONVENED.

Section 813 of the National Building Code adopted by the City of Slidell in Ordinance No. 679-1, Section 1 on April 2nd, 1963, is hereby enacted and added to Article 8 of the National Building Code to read as follows:

Section 813. Commercial and Public Buildings.


a. Every portion of all commercial and public buildings with construction starting after July 1, 1973, shall be within 400 feet of the nearest standard municipal fire hydrant.

b. Standard municipal fire hydrants required under the provisions of sub-section "a" above shall be installed by the owner at no expense or cost to the City.

Duly introduced and adopted this 22nd day of May, 1973.


Frank N. Cusimano, Mayor

ATTEST:


John R. Swenson, City Clerk